



CAUTION!
BURIED STREET LIGHTING CONDUIT

NOTES

All concrete to be five inches thick placed upon four inches of compacted 1½" T.B.

Concrete shall have no colors, texture stamping or steel reinforcement. Fiber reinforcement is allowed.

Sidewalk joints shall be uniformly spaced with joints no farther than six feet six inches, nor less than four feet eight inches apart.

See the handout, "Private Residential Paving", for clearance requirements to above ground structures and trees.

Vertical or rolled face curb shall be removed and replaced with depressed curb. At the property owner's option, the existing curb head may be sawed off (City approval must be obtained first) to provide a depressed curb entrance. Mountable curb may be removed and replaced with depressed curb at the owner's expense.

Replaced curb shall be installed in accordance with City of Oak Creek specifications including, but not limited to: removal limits, construction of curb return, tie bar installation, and joint spacing. Depressed curb shall have 1' tapers to match existing curb head.



City of Oak Creek
Department of Public Works

Drawn By: S. GALEWSKI	Scale: None
Appv. By: W. ST. JOHN	Date: 12/5/03 (Revised)
URBAN DRIVEWAY APPROACH	
RO-9	